



## QWZU.EX27094 Centrifugal Fire Pumps, End Suction

[Page Bottom](#)

### Centrifugal Fire Pumps, End Suction

[See General Information for Centrifugal Fire Pumps, End Suction](#)**FULLBLAZE MIDDLE EAST**

EX27094

Expansionist Area- Zarqa Free Zone

PO Box 19083

Amman, 11196 JORDAN

Rated Capacity GPM	Size In.	Model Dsg	Rated Net Pressure Range psi	Approx Speed RPM	Max Working Pressure psi
50	2.5x1.5	FBP-E-65/40	95-136	2900	200
100	2.5x1.5	FBP-E-65/40	91-131	2900	200
150	2.5x1.5	FBP-E-65/40	82-123	2900	200
150	3x2	FBE-E-80/50	110-140	2900	225
200	3x2	FBE-E-80/50	106-137	2900	225
250	3x2	FBE-E-80/50	98-133	2900	225
400	5x3	FBP-E-125/80	85-137	2900	225
450	5x3	FBP-E-125/80	83-137	2900	225
450	5x4	FBP-E-125/100	133-211	2900	290
500	5x3	FBP-E-125/80	82-136	2900	225
500	5x4	FBP-E-125/100	133-210	2900	290
750	5x4	FBP-E-125/100	126-204	2900	290

[Last Updated](#) on 2017-01-04[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".