



Certificate of Compliance

This certificate is issued for the following:

Centrifugal Fire Pumps - Axial Split-Case Type

FBP-S-80/270

FBP-S-100/310

FBP-S-125/290

(See Listing Attached)

Prepared for:

Fullblaze Middle East
Zarqua Free Zone New Expansionist Area
Amman 11192
Jordan

FM Approvals Class: 1311, dated January 2018

Approval Identification: 0003062763

Approval Granted: January 14, 2019

To verify the product continues to be Approved please refer to www.approvalguide.com.

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read "D.B. Fuller", is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group



Certificate of Compliance

Product	Listing Country	Rated Capacity, (gal/min)	Rated Capacity, (dm ³ /min)	Rated Net Head at Rated Capacity, psi	Rated Net Head at Rated Capacity, kPa	Rated Speed, r/min	Suction Inlet, dia., in.	Discharge Outlet, dia., in.	Stage(s)	Certification Type
FBP-S-80/270	Jordan	500	1893	106-170	731- 1172	2980	5	3	1	FM Approved
FBP-S-100/310	Jordan	750	2839	143-245	986- 1689	2980	6	4	1	FM Approved
FBP-S-100/310	Jordan	1000	3785	121-243	834-1675	2980	6	4	1	FM Approved
FBP-S-125/290	Jordan	1250	4732	133-206	917- 1420	2980	8	5	1	FM Approved
FBP-S-125/290	Jordan	1500	5680	136-201	938- 1386	2980	8	5	1	FM Approved



Member of the FM Global Group